

DEFROST CONTROLLERS - SAGINOMIYA




Electronic (De-Ice)

Airefrig Part Number	Operation Temp °C		Capillary Sensor mm		Contacts (250 Volts)		Max Temp C	Time Cycle Minutes	Time Safe	List Price Ex GST
	Start	Term	Bulb	Length	COM-NO	COM-NC				
DDEKBA1519RQ	-5	10	30 x 8	2000	5 amps	3 amps	60	30-180*	10-80**	\$142.25
DDEKDA1532RQ	-5	10	25 x 4.2	2000	20 amps	15 amps	60	30-180*	10-80**	\$134.04
DDEAA11RQ	Din Rail Adaptor (supplied with DDEKBA1519RQ & DDEKDA1532RQ)									\$35.48

* DDE Dip Switch Settings

Dip Switch Number			(Time Cycle) Defrost Mask time (Mins) *	Dip Switch Number			Time Safe (Mins) **
1	2	3		4	5	6	
Off	Off	Off	30	Off	Off	Off	10
On	Off	Off	40	On	Off	Off	15
Off	On	Off	50	Off	On	Off	20
On	On	Off	60	On	On	Off	30
Off	Off	On	90	Off	Off	On	40
On	Off	On	120	On	Off	On	50
Off	On	On	150	Off	On	On	60
On	On	On	180	On	On	On	80

Resetting of Dip Switches shall be done only when the power is OFF.
When power is left on set values do not change even after resetting power.



In case of forced defrost, make instantaneous short circuit between DEF terminals.
Continuous short circuit is prohibited