

VACUUM PUMPS

CPS Vacuum Pumps – Direct Drive

Airefrig Part Number	Description	Litres Per Minute	Micron	H.P.	List Price Ex GST
VP2DA	Vacuum Pump - 2 stage	45	10	1/4	\$528.00
VP2DE	Vacuum Pump - 2 stage	48	10	1/4	\$528.00
VP3DA	Vacuum Pump - 2 stage	75	10	-	\$742.50
VP4DE	Vacuum Pump - 2 stage	96	10	1/2	\$742.50
VP6DE	Vacuum Pump - 2 stage	144	10	1/2	\$973.50
VP8D	Vacuum Pump - 2 stage	192	10	2/3	\$1,305.00
VP10DA	Vacuum Pump - 2 stage	236	10	3/4	\$1,961.85
VP10D	Vacuum Pump - 2 stage	240	10	3/4	\$1,961.85
VP12D	Vacuum Pump - 2 stage	288	10	1.0	\$2,198.64

Airefrig Part Number	Description	List Price Ex GST
L340	Vacuum Pump Oil (945 mls)	\$21.32
L341	Vacuum Pump Oil (3.78 Litre)	\$42.77
CAB001	CPS A/C Power Cord for Vacuum pumps & Recovery units	P.O.A.
VG200	CPS Vacuum Gauge with Digital Display	\$640.92
AVT45	Tee 1/4M/F x 1/4 Female Flare Knurl x 1/4 M/F (suit VG200)	\$39.51
VPASU	Vac Pump Anti-Siphon Valve Kit (c/w 1/4,3/8,1/2MF Adaptors)	\$108.24



VG200 – Vacuum Gauge

- Advanced 5 digit LCD display
- Reads microns, Torr, in/hg or mBar at a touch of a button.
- Withstand 400PSI pressure.
- Carry case & hook included.



AVT45

Vacuum Pump Maintenance and Service Information

The vacuum pump consists of two cascaded stages driven by a common shaft. The first stage (or roughing stage) takes air/vapour via the inlet port, compresses it and exhausts through an exhaust port. The second stage takes from the inside of this exhaust port and also compresses the vapour and then exhausts this vapour out through a second exhaust port.

The purpose of a gas ballast valve (where fitted) is to bleed dry air into the second chamber at 0 PSIG or very close to it. This way the second stage draws in vapour, it's pressure is reduced and vapour is removed from the oil/vapour as the saturated vapour pressure is lowered. The second stage typically is also fed oil from the pump reservoir and when the pump is under ballast this oil is also exposed to the reduced pressure and this assists removal of moisture from the oil.

As the pump is working slightly harder when under ballast, more heat is also generated so allowing the oil which is being circulated through the second chamber to warm up and return to the reservoir so raising the temperature of the reservoir faster. This enables the pump to reach operating temperature faster. Remember, if the oil is cold the moisture pulled back can blend with the cold oil, overload the oil with moisture and in short order can wreck the pump. The idea is to get the pump **HOT**, this way moisture hits hot oil and is pushed straight out of the pump. A hot pump works better and will last longer than a pump which is never allowed to reach operating temperature.

To start and use the pump, ensure the ballast and inlet ports are both closed, turn the pump on. Once the pump is started open the ballast valve and leave to run like this for approximately ½ hour. When ready to use, close the ballast and connect to the system to be evacuated, open the suction port and evacuate the system. After the vacuum is complete, it is good practice to run the pump for a further 10 – 15 minutes under ballast again to remove impurities from the oil. An even better practice is to actually drain the oil from the pump, allow the pump to cool before adding fresh oil.

To drain the oil from the pump ensure it is on a level surface (preferable with the oil warm) and remove the drain plug from the pump. You may need to unscrew the exhaust chimney or oil inlet in order to allow air into the pump to allow oil flow. Inspect the oil for cloudiness, impurities and foreign lumps. When refilling, ensure pump is cool and refill to the correct level. **DO NOT overfill !!** If water is noticed in the pump you may need to refill, run under ballast for a short time, drain and refill in order to ensure the moisture is removed.

Not all pumps are identical in operation, always, as a first step, read the instructions that come with the pump.



FIELDPIECE INSTRUMENTS

ATIR3 Non-contact Infrared Temperature Accessory Head

Measures temperature without contact

- 8:1 field of view
- Laser sight included
- Select °F or °C
- Operating ambient temperature 32°F to 122°F (0C to 50C)
- Temperature measurement range 0°F to 752°F (-18C to 400C)
- Accuracy: Whichever is greater.
At 73°F ± 10°F at <90%RH
± 2.0%rdg. or 4°F , 32°F to 160°F
±3.0%rdg.or 5.5°F, 0°F to 31°F
161°F to 752°F.



ATIR3
Non-contact Infrared
Temperature Accessory Head

ADNM2 Dual-Port Manometer Accessory Head

Measure gas pressure and has resolution low enough for static pressure.

- Measures in mBar or WC. (water column).
- 0.01 or 0.1 depending on selected resolution.
- Manual zero-set for comparing two pressures.
- Includes tube and adaptor for gas pressure measurement.
- Auto-off can be disabled for data logging.



ADNM2
Manometer Head

AVG2 Digital Vacuum Gauge Accessory Head

Displays pressure in microns in steps of one micron.

Has pump down indication showing progress from atmospheric pressure

- Range: 50 to 2000 microns of mercury.
- Resolution (steps): 1 micron of mercury
- Pump down indication: output of head goes from over 3VDC at atmosphere to 2VDC at 2000 microns.
- Overload: 500 PSI
- Fitting: 1/4" flared brass fitting (male)
- Accuracy (73°F ±9°F): ±10%, 0 to 1000 microns, <90%RH
- Straight-in access to sensor for easy cleaning.
- New "T" for inline vacuum testing.
- LEDs indicate increasing, decreasing and stable vacuum.
- Auto-off can be disabled for data logging.



AVG2
Digital Vacuum
Gauge Accessory
Head

SVG2 Digital Stand Alone Vacuum Gauge

- Measures from 50-2000 microns.
- Auto off when left in Atmospheric pressure.
- High and low alarm that notifies user when the desired vacuum has been reached with bright red LED and audible alarm.
- Vacuum indicators notifies user if vacuum is decreasing, stable or increasing in pressure
- Fast response and high resolution Accuracy +/- 10 microns from 50 to 1000 microns.
- Rubber boot protection with magnetic hanger.



SVG2 Digital
Vacuum Gauge

AVH1 AC/DC Voltage Accessory Head

Records voltage using DL2 data logger or EHDL1 handle.

Accuracy; DC ±(0.5%rdg + 1dgt.)

AC ±(1.0%rdg + 4dgt.)

Max voltage: 600V AC or DC

Input impedance: 1M Ohm

Standard test leads plug in top



AVH1
Voltage Head

Note: Prices on last page of Fieldpiece Information